



Product Service

Attestation of Conformity

No. N8A 099333 0066 Rev. 02

Model(s):

- LR6-72HV-xxxM, (xxx=335-360 in step of 5)
 - LR6-60HV-xxxM, (xxx=280-300 in step of 5)
 - LR6-72PH-xxxM, (xxx=340-380 in step of 5)
 - LR6-60PH-xxxM, (xxx=285-315 in step of 5)
 - LR6-72HPH-xxxM, (xxx=365-395 in step of 5)
 - LR6-72HIH-xxxM, (xxx=365-395 in step of 5)
 - LR6-60HPH-xxxM, (xxx=300-325, in step of 5)
 - LR6-60HIH-xxxM, (xxx=300-325 in step of 5)
 - LR6-72OPH-xxxM, (xxx=385-415 in step of 5)
 - LR6-60OPH-xxxM, (xxx=335-365 in step of 5)
 - LR6-72HPH-xxxMC, (xxx=375-390 in step of 5)
 - LR6-60HPH-xxxMC, (xxx=305-325 in step of 5)
 - LR6-60ZPH-xxxM, (xxx=330-355 in step of 5)
 - LR4-72HPH-xxxM, (xxx=420-455 in step of 5)
 - LR4-72HIH-xxxM, (xxx=420-440 in step of 5)
 - LR4-60HPH-xxxM, (xxx=350-375 in step of 5)
 - LR4-60HIH-xxxM, (xxx=350-370 in step of 5)
 - LR4-72ZPH-xxxM, (xxx=420-435 in step of 5)
 - LR4-60ZPH-xxxM, (xxx=350-365 in step of 5)
- xxx is standing for rated output power at STC

Parameters:

Fire Safety Class:	Class C according to UL790
Safety Class:	Class II
Maximum System Voltage:	1500V DC
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute. No.10 West Kaifa Road, Yangzhou, 225009 Jiangsu, P.R.China.
Construction:	Framed, with Junction box, cable and connector.

Tested according to:

- EN IEC 61730-1:2018
- EN IEC 61730-1:2018/AC:2018-06
- EN IEC 61730-2:2018
- EN IEC 61730-2:2018/AC:2018-06

Page 2 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.

ZERTIFIKAT • CERTIFICATE • 認證書 • CERTIFICADO • CERTIFICAT